



State Environment Impact Assessment Authority, M.P.
(Government of India, Ministry of Environment, Forest & Climate Change)
Environmental Planning Coordination Organization (EPCO)
Paryavaran Parisar, E-5. Arera Colony
Bhopal-4620 16

visit us <http://www.mpseiaa.nic.in>
Tel:0755-2466970, 2466859
Fax : 0755-2462136

No: 5691 /SEIAA/2017
Date: 25.3.17

To,
Shri Vivek Maheshwari, Director
Village Thaini, Post Bankhedi,
District Hoshangabad,
MP – 461990

Sub:- Case No.4963/2016 : Prior Environmental Clearance for Proposed 30 MW Bagasse Based Cogeneration Power Plant at Khasra No. 132/1C, 133, 135/1, 132/1B, 132/1D, 134, 135/2, 132/1A, Village - Pondar, Tehsil- Salichouka, District- Narsinghpur, (MP) Total Power Plant area- 4.804 ha by M/s Narmada Sugar Pvt. Ltd. through Director Shri Vivek Maheshwari, Village Thaini, Post Bankhedi, District Hoshangabad, MP – 461990, E-mail nsplpower@gmail.com, Phone No. 07576-228888, 228899 Env't. Consultant- Creative Enviro Services

Ref: Your application dtd.28.01.16 received in SEIAA office on 04.02.2016

With reference to above, the proposal has been appraised as per prescribed procedure & provisions under the EIA notification issued by the Ministry of Environment & Forests vide S.O.1533(E), dtd. 14.09.06 & its amendments, on the basis of the mandatory documents enclosed with the application viz., Form I, pre-feasibility report, ToR & EIA Report and additional clarifications furnished in response observations by the State Expert Appraisal Committee (SEAC) and State Environment Impact Assessment Authority (SEIAA) constituted by the competent Authority.

- (i) The proposed project is bagasse based cogeneration power plant in an area of 4.77 ha for production capacity 30 MW at Village - Pondar, Tehsil- Salichouka, District Narsinghpur (MP). The proposed plant will be designed to produce surplus power after meeting the entire requirements of steam of the sugar mill, both during season and off season period.
- (ii) The project is covered under category B Project Activity 1(d) of the EIA Notification issued by the Ministry of Environment & Forests vide S.O.1533 (E), dtd. September 14, 2006 and subsequent amendments.
- (iii) There is no interstate boundary within 10 km and no National Park / Sanctuary within the 5 km of the project area hence the general conditions are not attracted.
- (iv) Total 40 acres land is in possession of proponent for sugar plant and further 4.804 ha land has been acquired for installation of CPP unit. As per Khasra Panchsala (2014-15) the land is the name of, Shri Vineet Kumar Director M/s Narmada Sugar Pvt. Ltd.
- (v) Public Hearing was conducted within the Narmada Sugar Pvt. Ltd. plant area, Village- Pondar, Tehsil- Salichouka, District Narsinghpur (M.P) on 07.11.2016 under Chairmanship of ADM, Narsinghpur. The issues raised during the public hearing were mainly related to employment, adverse impact over the environment, air emission from stacks, disposal of waste water generated from sugar plant, ground water table and adverse effect on fertility of land from the unit, which were addressed by PP.

(vi) The major raw materials of the proposed plant are as follows:

Item	Value	
	Season	Off season
Crushing rate, TCH	227.27	-
Bagasse generation at 29.00 % on cane, TPH	65.91	-
Bagacillo / handling loss at 0.80 % on cane, TPH	1.82	-
Bagasse available as fuel at 28.20 % on cane, TPH	64.09	-
Total equivalent bagasse available, MT	225600	-
Bagasse required by new boiler, TPH (MT)	55.15 (211776)	43.75 (43650)
Bagasse saved / available for off season operation, MT	-	13824
Bagasse saved / available for off season operation, MT	-	30000
Days on procured bagasse from group sugar Mills	-	29

- (vii) PP has proposed the fuel for the cogeneration power plant operation will be bagasse which will be met from parent sugar plant. The bagasse handling system shall be designed for a capacity of about 90 TPH.
- (viii) Steam Requirement for sugar crushing of upto 150 TPH which will be supplied by proposed cogen plant.
- (ix) PP has obtained connectivity to 30 MW Bagasse based Power Plant from the Office of the Commissioner, New and Renewal Energy vide letter dated 05.11.15.
- (x) The source of the water is ground water. The total water requirement is 724 KLD. Out of total requirement, only 74 KLD of ground water shall be abstracted for the purposes of CPP and remaining 650 KLD water will be available as condensate from sugar manufacturing unit. PP has submitted NOC from Central Ground Water Authority, Ministry of Water Resources, GoI vide letter No. 21-4/338/MP/IND/2016-316 dated 16.2.17 for ground water withdrawal in respect of their power generation unit
- (xi) Waste water will be generated from the cooling towers, boilers and from domestic activities. PP has proposed Boiler blow down will be neutralized in neutralization tank and mix with CT blow down and will be reuse in horticulture activity/Ash conditioning. Domestic effluent after treatment in the Sewage Treatment Plant (50 KLD Capacity) will be reused for horticulture purpose/ flushing. Hence no effluent discharge will take place.
- (xii) For the control of air pollution PP has proposed as follows:
- ESP will be provided at stack of boiler to control the emission below 150 mg per cubic meter.
 - Provision of fuel stack of 75m height for wider dispersion of gaseous emission.
 - Dust collectors system shall be provided at various material transfer points. Transfer Points and Conveyors will be provided with dry extracting system facilitated with Bag Filters.
 - Dense plantations will be developed in and around the plant over area of 2 acres.
 - Ambient air quality and stack emission will be regularly monitored to ensure that ambient air quality meets the given standards.
 - All the unpaved roads as well as paved roads will be sprinkled with water.
 - Plugging all leakages and enclosing storage and material handling systems.
 - Screen house shall be totally enclosed with brick-sheet walls and covered with sheet roofing.
- (xiii) Solid Wastes generated from the process activities will be mainly discarded bags/containers, waste papers, broken glass bottles etc. which is proposed to sold off to authorized vendors/recyclers. Sludge from STP will be used as manure. Hazardous wastes like used oil, Resin from cooling towers, Reject

Carbons and discarded drums are proposed to be stored in HDPE drums and given to re-processor or disposal at TSDf, Pithampur authorized by MPPCB/MoEF. Fly ash from boiler either mixed with press mud and will be given to farmers or will be send to cement manufacturing unit.

- (xiv) PP has proposed Rain Water Harvesting system in plant area to recharge ground water. At present four bore wells and one dug well are the ground water source in the project area. In addition to these 20 recharge pits and 05 recharge pits with well are proposed for recharge to ground water.
- (xv) PP has submitted traffic movement plan at State Highway/internal approach road and raw material storage yard area.
- (xvi) PP has included risk assessment, emergency plan, health and safety and fire fighting in the EIA report.
- (xvii) PP has submitted that green belt has been developed within the existing sugar premises covering an area of about 2 acres with 100 numbers of plants which is adjacent to the proposed site. PP has proposed to develop green belt over 15850 sq. m. of land with 3200 numbers of trees upto 5 years to comply with the guideline of MoEF.
- (xviii) Under CSR activities, PP has proposed Vocational and skill development training for boys & girls, ensuring safe drinking water and healthy sanitation practices, Agriculture improvement camps and infrastructure facility to nearby schools with budgetary provision of 6.70 lakh/year.

Based on the information submitted at Para i to xviii above and others, the State Level Environment Impact Assessment Authority (SEIAA) considered the case in its 414th meeting held on 08.03.2017 and decided to accept the recommendations of 286th dtd SEAC meeting held on dtd 28.01.2017.

Hence, Prior Environmental Clearance is accorded under the provisions of EIA notification dtd. 14th September 2006 to the Proposed 30 MW Bagasse Based Cogeneration Power Plant at Khasra No. 132/1C, 133, 135/1, 132/1B, 132/1D, 134, 135/2, 132/1A, Village - Pongar, Tehsil- Salichouka, District- Narsinghpur, (MP) Total Power Plant area- 4.804 ha by M/s Narmada Sugar Pvt. Ltd. through Director Shri Vivek Maheshwari, Village Thaini, Post Bankhedi, District Hoshangabad, MP – 461990,,subject to the compliance of the Standard Conditions enclosed at Annex-I and the following additional Specific Conditions as recommended by SEIAA & SEAC in its meetings.

A. Specific Conditions as recommended by SEIAA

1. For controlling fugitive natural dust, regular sprinkling of water & wind shields at appropriate distances in vulnerable areas of the plants shall be ensured.
2. PP shall ensure that the treated effluent and stack emissions from the unit are within the norms stipulated under the EPA rules of MPCB whichever is more stringent. In case of process disturbances/failure of pollution control equipment adopted by the unit, the respective unit shall be shut down and shall not be restarted until the control measures are rectified to achieve the desired efficiency.
3. The particulate emissions shall conform to the prescribed standards. The emissions from the DG sets shall be dispersed through stack of adequate height as per M.P.Pollution Control Board standards. Acoustic enclosures shall be provided to mitigate the noise pollution.
4. Adequate number of influent and effluent quality monitoring stations shall be set up in consultation with the Sate Pollution Control Board. Regular monitoring should be carried out for relevant parameters.

5. Regular monitoring of the air quality, including SPM & SO₂ levels both in work zone and ambient air shall be carried out in and around the power plant and records shall be maintained. The location of monitoring stations and frequency of monitoring shall be decided in consultation with M.P. Pollution Control Board (MPPCB) & suit report accordingly to MPPCB.
6. A detailed scheme for rainwater harvesting shall be prepared and implemented to recharge ground water. PP shall ensure to develop proper rainwater harvesting system with recharge pits in existing Sugar Mill and in nearby villages.
7. Bagasse storage should be properly compressed and covered.
8. PP shall develop green belt over 15850 sq. m. of land with 3200 numbers of trees. PP shall also ensure to develop three tier green belt all around the premises.
9. Internal roads and raw material storage yard area of the plant should be properly concrete/pakka to reduce dust emission.
10. Leq of noise level shall be maintained as per standards. For people working in the high noise area, requisite personal protective equipment like earplugs etc. shall be provided.
11. The overall noise levels in and around the plant are shall be kept well within the standards by providing noise control measures including acoustic hoods, silencers, enclosures etc. on all sources of noise generation. The ambient noise levels shall conform to the standards prescribed under Environment (Protection) Act, 1986 and Rules 1989.
12. Adequate safety measures shall be provided to limit the risk zone within the plant boundary, in case of an accident. Leak detection devices shall also be installed at strategic places for early detection and warning.
13. The company shall undertake following waste minimization measures:
 - a. Metering of quantities of active ingredients to minimize waste.
 - b. Reuse of by products from the process as raw materials or as raw material sub situates in other process.
 - c. Maximizing recoveries.
 - d. Use of automated material transfer system to minimize spillage.
 - e. Use of "close feed" system into batch reactors.
14. Regular mock drills for the on-site emergency management plan shall be carried out. Implementation of changes/improvements required. If any, in the on-site management plan shall be ensured.
15. Transportation of ash will be through closed containers and all measures should be taken to prevent spilling of the ash.
16. Separate silos will be provided for collecting and storing bottom ash and fly ash.
17. Appropriate budget provision for concreting the internal road and raw material storage yard area be made in EMP.
18. PP should ensure vocational and Skill Développement training for boys & girls, ensuring safe drinking water and healthy sanitation practices, Agriculture improvement camps, infrastructure facility to nerarby schools and rain water harvesting in nearby villages with budgetary provision of 6.70 lakh/year under CSR activities.

B. Specific Conditions as recommended by SEAC

19. The EC shall be valid for production of 30 MW Bagasse Based Cogeneration Power Plant.

20. To control the particulate emission from the boiler, Hybrid ESP meeting 50 mg/Nm³ shall be installed.
21. On-line continuous monitoring systems for emission monitoring should be installed and data connectivity must be provided to the MPPCB's server for remote operations.
22. Bag filters shall be provided for control of fugitive emissions from the ash handling areas.
23. A stack of 75 m height shall be installed.
24. The project proponent shall undertake rain water harvesting measures and shall develop water storage for use in operation of the plant. Rain water harvesting system shall be put in place which shall comprise of rain water collection from the built up and open area in the plant premises.
25. Fly ash generated shall be provided to farmers to be used as manure or disposed of as per Fly Ash Utilization Notification, 1999 and as amended subsequently.
26. Green Belt consisting of 3 tiers of plantations of native species around the plant boundary comprising of atleast 33% of total land for both sugar plant and proposed thermal power plant shall be raised. The density of trees shall not be less than 2500 per Ha and rate of survival atleast 80%.
27. No water bodies (including natural drainage system) in the area shall be disturbed due to activities associated with the setting up / operation of the power plant.
28. Monitoring surface water quality in the area shall also be regularly conducted and records maintained. The monitored data shall be submitted to the M.P. Pollution Control Board regularly.
29. The treated effluents conforming to the prescribed standards only shall be re-circulated and reused within the plant. Arrangements shall be made that effluents and storm water do not get mixed.
30. A sewage treatment plant shall be provided and the treated sewage shall be used for raising greenbelt/plantation.
31. Noise levels emanating from turbines shall be so controlled such that the noise in the work zone shall be limited to 85 dB(A) from source. For people working in the high noise area, requisite personal protective equipment like earplugs/ear muffs etc. shall be provided. Workers engaged in noisy areas such as turbine area, air compressors etc shall be periodically examined to maintain audiometric record and for treatment for any hearing loss including shifting to non noisy/less noisy areas.
32. Regular monitoring of ambient air ground level concentration of SO₂, NO_x, PM_{2.5} & PM₁₀ shall be carried out in the impact zone and records maintained. The location of the monitoring stations shall be decided in consultation with M.P. Pollution Control Board. Periodic reports shall be submitted to the Regional Office of this Ministry and M.P. Pollution Control Board.
33. Well designed acoustic enclosures for the DG sets and noise emitting equipments to achieve the desirable insertion loss viz. 25 dB(A) should be provided.
34. Ultrasonic/Magnetic flow/Digital meters shall be provided at the inlet and outlet of the proposed treatment plants & all water abstraction points and records for the same shall be maintained regularly.
35. All the commitments made in the Public Hearing shall be implemented by PP and adequate budget provision shall be made accordingly.



36. PP shall be responsible for discrepancy (if any) in the submissions made by the PP to SEAC & SEIAA.
37. Necessary consents shall be obtained from MPPCB and the air / water pollution control measures have to be installed as per the recommendation of MPPCB.
38. As proposed, no effluent shall be discharged outside the plant premises and Zero discharge shall be maintained. PP should also install Internet Protocol PTZ camera with night vision facility along with minimum 05X zoom and data connectivity must be provided to the MPPCB's server for remote operations.
39. First Aid and sanitation arrangements shall be made for the drivers and other contract workers during construction phase.
40. The project proponent shall also adequately contribute in the development of the neighboring villages. Special package with implementation schedule for providing potable drinking water supply in the nearby villages and schools shall be undertaken in a time bound manner.
41. No parking of vehicles should be done outside the factory premises of vehicles carrying the sugarcane crop.
42. PP should explore the possibility of installing "Baggas Drying System".
43. The validity of the EC shall be as per the provisions of EIA Notification subject to the following: Expansion or modernization in the project, entailing capacity addition with change in process and or technology and any change in product - mix in proposed mining unit shall require a fresh Environment Clearance.

5698
Endt No. / SEIAA/ 2017

Dated 25.3.12

OC
Dain
(Anupam Rajan)
Member Secretary

Copy to:-

- (1). Principal Secretary, Urban Development & Environment Deptt. 3rd Floor, Mantralaya Vallabh Bhawan, Bhopal.
- (2). Secretary, SEAC, Research and Development Wing Madhya Pradesh Pollution Control Board, Paryavaran Parisar, E-5, Arera Colony Bhopal-462016.
- (3). Member Secretary, MPPCB, Paryavaran Parisar, E-5, Arera Colony, Bhopal-462016.
- (4). The Collector, District Narsinghpur, M.P.
- (5). Managing Director, M.P. Audyogik Kendra Vikas Nigam (Jabalpur) Limited, 447, Napier Town Jabalpur(M.P.) 482001.
- (6). Director, I.A. Division, Monitoring Cell, MoEF, Gol, Ministry of Environment & Forest Indira Paryavaran Bhawan, Jor Bagh Road, New Delhi – 110 003
- (7). Director (S), Regional office of the MOEF, (Western Region), Kendriya Paryavaran Bhawan, Link Road No. 3, Ravi Shankar Nagar, Bhopal-462016.
- (8). Guard file.

Encl: Standard Conditions (Annex-I)

OC
Sanjeev Sachdev
(Dr. Sanjeev Sachdev)
Officer-in-Charge


State Environment Impact Assessment Authority, M.P.

(Government of India, Ministry of Environment & Forests)
Research and Development Wing, Madhya Pradesh Pollution Control Board,
Paryavaran Parisar, E-5. Arera Colony, Bhopal-4620 16


Annex-I

Standard Conditions related to Activity 1 (d) - Thermal Power Plants of Category B projects under the Schedule of Ministry of Environment and Forests, GoI notification dtd 14-09-06

1. Any enhancement of capacity, change in technology, modernization and scope of working shall again require prior environmental clearance as per EIA notification, 2006.
2. All activities / mitigative measures proposed by PP in Environmental Impact Assessment and must be ensured.
3. All activities / mitigative measures proposed by PP in Environmental Management Plan and approved by SEAC must be ensured.
4. All parameters listed in Environmental Monitoring Plan approved by SEAC must be monitored at approved locations and frequencies.
5. Vehicular emissions shall be kept under control and regularly monitored. Vehicles used for transportation of raw material and others shall have valid permissions as prescribed under Central Motor Vehicle Rules, 1989 and its amendments. No overloading of raw material for transportation shall be committed.
6. The industry has to keep strict vigilance on the Fugitive emission and shall ensure that the ambient air quality is well within the prescribed norms by MoEF/ CPCB.
7. Four ambient air quality-monitoring stations shall be established for RSPM, SPM, SO₂, NO_x monitoring. Location of the stations should be decided based on the meteorological data, topographical features and environmentally and ecologically sensitive targets and frequency of monitoring should be undertaken in consultation with the State Pollution Control Board. The monitored data for criteria pollutants shall be regularly up loaded and displayed on the company's website.
8. Data on ambient air quality (RPM, SPM, SO₂, NO_x) should be regularly submitted to the Regional office, MoEF, GoI, Bhopal and the State Pollution Control Board / Central Pollution Control Board once in six months.
9. Ambient air quality at the boundary of the plant premises shall conform to the norms prescribed in MoEF notification no. GSR/826(E) dtd. 16.11.09.
10. Closed Cycle Cooling system with cooling towers shall be provided.
11. The waste water (workshop) should be properly collected, treated so as to conform to the standards prescribed by MoEF & CPCB under GSR 422 (E) dated 19th May, 1993 and 31st December, 1993 or as amended from time to time. Oil and grease trap shall be installed.
12. The treated effluents conforming to the prescribed standards shall be re-circulated and reused within the plant boundary. There shall be zero discharge outside the plant boundary.


3-8-13

(Dr. U. M. Shukla)
Officer-in-Charge


3-8-13


(Dr. R. K. Jain)
Officer-in-Charge


1 of 3

State Environment Impact Assessment Authority, M.P.

(Government of India, Ministry of Environment & Forests)
Research and Development Wing, Madhya Pradesh Pollution Control Board,
Paryavaran Parisar, E-5. Arera Colony, Bhopal-4620 16

13. Regular monitoring of ground water quality including heavy metals shall be undertaken in the project area and around the ash pond to ascertain the change, if any, in the water quality due to leaching of contaminants, if any, from the ash disposal area.
14. Measures shall be taken for control of noise levels below 75 dBA in the work environment. Workers shall be provided with ear plugs / muffs.
15. Wherever possible, the area around the STP / ETP should be surrounded with dense green belt.
16. Occupational health and safety measures for the workers including identification of work related health hazards, training on malaria eradication, HIV, and health effects on exposure to mineral dust etc. shall be carried out. Periodic monitoring for exposure to respirable mineral dust on the workers shall be conducted and records maintained including health records of the workers. Awareness programme for workers on impact of mining on their health and precautionary measures like use of personal equipments etc. shall be carried out periodically. Review of impact of various health measures shall be conducted followed by follow up action wherever required.
17. Personnel working in dusty areas shall be provided with protective respiratory devices and they shall also be imparted adequate training and information on safety and health aspects.
18. Industry should promote CDM projects as and where possible.
19. Use of Solar Energy should be promoted in the plant premises where ever possible.
20. Commitment towards CSR have to be followed strictly.
21. The Project Proponent shall provide proper arrangement for the disposal of hazardous waste (if any) and obtain authorization under Hazardous Waste (Management Handling & Transboundary Movement) Rules 2008 from MPPCB.
22. Concrete measures shall be taken for prevention of solid waste from the premises into nearby land.
23. A separate Environmental Management Cell with suitable qualified personnel shall be set-up under the control of a Senior Executive, who will report directly to the Head of the Organization.
24. Project Proponent has to strictly follow the direction/guidelines issued by MoEF, CPCB and other Govt. Agencies from time to time.
25. The funds earmarked for environmental protection measures shall be kept in separate account and shall not be diverted for other purpose. Year wise expenditure shall be reported to the MoEF, Gol, and its Regional Office located at Bhopal.
26. The Regional Office, MoEF, Gol, Bhopal & MPPCB shall monitor compliance of the stipulated conditions. A complete set of documents including Environment Impact Assessment Report, Environmental Management Plan, should be given to Regional Office, MoEF, Gol, Bhopal & MPPCB.
27. Action plan with respect to suggestion/improvement and recommendations made and agreed during public hearing consultation shall be submitted to the Regional Office, MoEF, Gol, Bhopal, MP PCB within six months.
28. A copy of the environmental clearance shall be submitted by the Project Proponent to the Heads of the Local Bodies, Panchayat and Municipal Bodies as applicable in addition to the associated Government Departments responsible for controlling the proposed projects who in turn has to display the same for 30 days from the date of receipt.


(Dr. U. M. Shukla)
Officer-in-Charge


(Dr. R. K. Jain)
Officer-in-Charge


2 of 3


State Environment Impact Assessment Authority, M.P.

(Government of India, Ministry of Environment & Forests)
Research and Development Wing, Madhya Pradesh Pollution Control Board,
Paryavaran Parisar, E-5. Arera Colony, Bhopal-4620 16

29. The Project Proponent shall advertise at least in two local newspapers widely circulated, one of which shall be in the vernacular language of the locality concerned, within 7 days of the issue of the clearance letter informing that the project has been accorded environmental clearance and a copy of the clearance letter is available with the State Pollution Control Board and also at web site of the State Level Environment Impact Assessment Authority (SEIAA) website at www.mpseiaa.nic.in and a copy of the same shall be forwarded to the Regional Office, MoEF, Gol, Bhopal.
30. The Project Proponent has to submit half yearly compliance report of the stipulated prior environmental clearance terms and conditions in hard and soft copy to the Regulatory Authority, viz. CPCB, MPCB and Regional office of MoEF, Gol at Bhopal on 1st June and 1st December of each calendar year.
31. Full Cooperation should be extended to the Officers and staff from the Ministry and its Regional Office at Bhopal / the CPCB / the SPCB during monitoring of the project.
32. The SEIAA of M.P. reserves the right to add additional safeguard measures subsequently, if found necessary, and to take action including revoking of the environment clearance under the provisions of the Environmental (Protection) Act, 1986, to ensure effective implementation of the suggested safeguard measures in a time bound and satisfactory manner.
33. The Ministry or any other competent authority may alter/modify the above conditions or stipulate any further condition in the interest of environment protection.
34. These stipulations would be enforced among others under the provisions of Water (Prevention and Control of Pollution) Act, 1974, the Air (Prevention and control of Pollution) Act 1981, the Environment (Protection) Act, 1986, the Public Liability (Insurance) Act, 1991 and EIA Notification, 2006.
35. Concealing factual data or submission of false/fabricated data and failure to comply with any of the conditions mentioned above may result in withdrawal of this clearance and attract action under the provisions of Environment (Protection) Act, 1986.
36. The Environmental Clearance shall be valid for a period of five years from the date of issued of this letter.
37. Any appeal against this prior environmental clearance shall lie with the Green Tribunal, if necessary, within a period of 30 days as prescribed under Section 16 of the National Green Tribunal Act, 2010.
38. The above conditions will be enforced inter-alia, under the provisions of the Water (Prevention & Control of Pollution) Act, 1974, the Air (Prevention & Control of Pollution) Act, 1981, the Environment (Protection) Act, 1986 and the Public Liability Insurance Act, 1991 along with amendments and rules.
39. The proponent shall upload the status of compliance of the stipulated EC conditions, including results of monitored data on their website and shall update the same periodically. It shall simultaneously be sent to the Regional Office of MoEF, the respective Zonal Office of CPCB and the SPCB. The criteria pollutant levels namely; SPM, RSPM, SO₂, NO_x (ambient levels as well as stack emissions) or critical sectoral parameters, indicated for the project shall be monitored and displayed at a convenient location near the main gate of the company in the public domain.
40. The environmental statement for each financial year ending 31st March in Form-V as is mandated to be submitted by the project proponent to the concerned State Pollution Control Board as prescribed under the Environment (Protection) Rules, 1986, as amended subsequently, shall also be put on the website of the company along with the status of compliance of EC conditions and shall also be sent to the Regional Office of MoEF.

3 of 3


(Dr. U. M. Shukla)
Officer-in-Charge


(Dr. R. K. Jain)
Officer-in-Charge

1 (d) - Thermal Power Plants

Issued Vide No. 5691/98 SEIAA/EPCO
Dated. 25.3.12